



Shenzhen Toby Technology CO.,Ltd.

1A/F, Bldg.6, Yusheng Industrial Zone, The National Road No.107
Xixiang Section 467, Xixiang, Bao'an, Shenzhen, Guangdong
Tel: 0755-26509301 Fax: 0755-26509195 www.tobylab.cn



CERTIFICATE OF CONFORMITY

Certificate No.: TB190822754

Applicant : Shenzhen Terpres Technology Co. LTD.
Address : 15C Yuehua Garden, Donggui Miao Road, Nanshan Road, Nanshan District, Shenzhen, China
Manufacturer : Shenzhen Terpres Technology Co., LTD.
Address : 15C Yuehua Garden, Donggui Miao Road, Nanshan Road, Nanshan District, Shenzhen, China
Product : Power Distribution Unit
Brand Name : GWGJ
Model(s) : XY110108Z13, XY110108Z13-7, XY110108Z13-8, XY110108Z13-06, XY110108Z13-07, XY110108Z13, XY110108Z11, XY110108Z12, XY110108G13, XY110108G16, ZN12, ZN12-1, XY-G10-U, XY-G10-D, XY-G10-K, XY-G10-S, XY-G10-F, XY-G10-H, XY-G10-M, QIT-01, QIT-02, QIT-03, QIT-04, QIT-05, QIT-06, QIT-07.

Test Standard(s):

EN 55032: 2015;
EN 61000-3-2: 2014;
EN 61000-3-3: 2013;
EN 55024: 2010+A1: 2015.

The EUT described above has been tested by us with the listed standards according to the Council Directive 2014/30/EU relating to electromagnetic compatibility, and found in compliance with all essential requirements of the Directive. It is possible to use CE marking to demonstrate the compliance with the EMC Directive.

The certificate applies to the tested sample above mentioned only and shall not imply an assessment of the whole production. It is only valid in connection with the test report number: TB-EMC168413.

